




## Miami-Dade County Fire Rescue Department

## Effective September 1, 2005, in accordance with NFPA 1: 10.12.1, 10.12.2 and 10.12.3

- <u>NEW AUTOMATIC GATED ENTRYWAYS</u> to residential communities or multi-family complexes and commercial properties with keyed automatic entryways may use only a Knox key switch (model 3502) to allow responding emergency personnel access to the property. <u>No other system or model will</u> be permitted.
- EXISTING AUTOMATIC GATED ENTRYWAYS to residential communities or multi-family complexes and commercial properties that employ any method of access to emergency personnel other than a functional toggle switch in a Supra Max box will be required to upgrade to a Knox key switch system (model 3502). No other system or model will be permitted.
- MANUAL GATED ENTRYWAYS to commercial properties, where padlocks are used and are allowed by code, shall also use a Knox padlock (model 3753) along with the owner's padlock to allow responding emergency personnel access to the property. No other system or model will be permitted.

Knox key switch (model 3502) or padlock (model 3753) can be purchased from the Knox Company at website <a href="http://www.knoxbox.com/store/">http://www.knoxbox.com/store/</a> or telephone number <a href="mailto:(800) 552-5669">(800) 552-5669</a> extension #1.

The customer service representative must be told the key switch or padlock being ordered is for use in "Miami-Dade Fire Rescue" jurisdiction (system code #PS-31-291-08-05).







**Padlock**